



Electrical Work– WELL Sheet

WELL Sheet #: 1030
Revision: 2021/11

Date:		Job:		:		
Observation team member:				Signature:		
Observation team member:				Signature:		
Observation team member:				Signature:		
Location of Work:				Yes	No	N/A
1.	Working live on an electrical system is only conducted when there is no reasonable alternative.					
2.	Electrical workers are properly trained / qualified.					
3.	Appropriate electrical safety PPE is selected and worn for the tasks performed (i.e. flame resistant clothing to protect against arc flash hazards, voltage rated gloves tested and certified by a qualified electrical testing laboratory every six months).					
4.	All tools are protected with insulation.					
5.	An energized electrical work permit is thoroughly completed each time energized work is conducted.					
6.	Work areas are safely barricaded to prevent unauthorized access.					
7.	A permit/JSA is completed and communicated prior to performing electrical work.					
8.	Electrical workers and potential rescue personnel are trained in First Aid / CPR / AED.					
	NOTE: Consult with Total Health & Safety (Safety Specialist) and/or other SME(s) as necessary to verify these criteria.					
Comments:						